

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1130:186 Page 1 of 1

CATEGORY: Duct Smoke Detector Housings/Bases

LISTEE: Honeywell Inc., 1500W. Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403

DESIGN: Model SIGA-DH Duct Smoke Detector Units. Unit consists of a metal enclosure, relay, electrical components, a separately listed open area detector, a detector base and a sampling and exhaust tubes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Air velocity range: 300-4000 fpm

Model SIGA-DH with Model SIGA-IPHS detector head, the sensitivity must be set at Levels 1 through 4 for velocities over 1000 fpm.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as duct smoke detector housing units for use with separately listed compatible fire alarm control units.

XLF: 3240-1388:104

07-10-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager